

INSPECTION SCHEDULE

NOTE: Work shall not continue before inspection of the below phases. If the applicant/contractor moves beyond these points without inspection, they will be subject to removal of finishes. (Initial)_____

- Worksite prior to the issuance of a permit
- Footings (verify rebar)
- Foundation (verify rebar)
- Concrete slab
- Framing; structural
- Electrical, third party
- Plumbing, mechanical, fire-protection, and other similar service systems of the building
- Fire resistant construction, fire resistant penetrations
- Solid fuel-burning heating appliances, chimneys, flues, or gas vents
- Energy Code compliance, including but not limited to insulation, fenestration, air leakage, system controls, mechanical equipment size, and, where required, minimum fan efficiencies, programmable thermostats, energy recovery, whole-house ventilation, plumbing heat traps, high-performance lighting, and controls
- Installation, connection, and assembly of factory manufactured buildings and manufactured homes
- Final inspection after all work authorized by the building permit has been completed

Applicant: (print) _____

Sign: _____ Date: _____

Colin Mangan, NYS Code Enforcement Official 518-545-7433

CALL FOR INSPECTIONS